

# «Energy Storage and Island Systems»



*SE Europe Energy Dialogue Athens 9-10 December 2020*

A Presentation by A. Perellis, Researcher, IENE

INSTITUTE FOR ENERGY FOR  
SE EUROPE




## Presentation's Contents

---

- Renewable Electricity as the Sole Energy Carrier in Non Interconnected Islands
- The design of a New Energy system for the island of Kastellorizo
- IENE Study: “Feasibility Study of Energy Storage Systems’ Integration in Crete” (M53)

# Renewable Electricity as the sole energy carrier in Non Interconnected Islands (NIIs)

- Today, all NIIs are overwhelmingly dependent, by more than 80%, by oil-fired thermal power plants for power generation.
- EU Directive 2015/2193 for on the limitation of emissions of certain pollutants into the air from medium combustion plants is in effect, expected to lead to withdrawal of oil-fired power generating units from NII systems.
- Very high cost of operation for Autonomous oil-fired Thermal Power Plants in Small Non Interconnected Islands (Ag. Efstratios, Agathonisi, Anafi, Antikythera, Arkioi, Gavdos, Donousa, Ereikousa, Megisti, Othonoi)
  - Average annual full generation costs for 2019 amounted to €1,421.2/MWh on the island with the lowest demand (Antikythera) and €535.39 /MWh on the island with the highest demand (Megisti)
  - Average annual electricity generation costs for the last six years 2014 - 2019 range from €1,309.54 /MWh (Antikythera) to €466.75 /MWh (Megisti) respectively.
  - Average Monthly Variable Generation Costs range from €235.46 to €432.13 /MWh for 2019 and from €188 to €686 /MWh for the period 2014 - 2019. (While the average annual marginal price for electricity in the interconnected system was €64.35 /MWh in 2019)




# Energy Transition of the Island of Kastellorizo




# The design of a New Energy system for the island of Kastellorizo

- ❑ **High Penetration of available RES in the energy mix:** Solar and Wind power
- ❑ **Uninterrupted electricity supply for all consumers:** Domestic and Commercial Consumption
- ❑ **Uninterrupted water supply:** uninterrupted coverage of electricity demand for desalination facilities (flexibility through demand response)
- ❑ **Electric Mobility:** coverage of EV charging demand
- ❑ **Improvement of Energy Efficiency:** Utilization of non-electric RES (solar thermal) applications, more energy efficient end-use devices, more efficient lamps for lighting of public spaces.
- ❑ **Use of Energy Storage system:** to achieve high RES penetration while ensuring security of supply. Lithium-ion battery storage systems were the primary focus due to their continuously decreasing cost, fast response (immediate high power supply) and sufficient storage capacity.



# Sizing Methodology for the RES – Energy Storage system for Kastellorizo Island I



- Evaluation of available RES potential
- Selection of reference RES technologies
- Formulation of RES installed capacity scenarios
- Scenario Performance Analysis
- Sizing of Electricity Storage system with the use of special modeling tool (“Bat-op”).
- System simulation and performance analysis

## System’s Performance Optimizations

- Demand Side management (DSM) performed for desalination energy demand.
- Reduction of electricity demand by replacing electric water heaters with solar thermal systems

Figure 7.7 Flow diagram for the design process of the autonomous RES-storage system for the island of Megisti (Kastellorizo)

# Sizing Methodology for the RES – Energy Storage system for Kastellorizo Island II




Figure E1: Hourly Power Generation from RES for the selected scenario in January [kWh]




Figure E2: Hourly Power Generation +Surplus/-Deficit for the Power System of Megisti (Kastellorizo) (2025) for the selected scenario in January [MWh]




Figure E3: Results of the optimal required (minimum) system battery capacity, and the System's Deficits and Energy Curtailment [kWh] for specific RES penetration [%] using the Bat-Op software for January




Figure E4: Performance of Integrated RES - Electricity Storage Power Sources for January

# The New Energy System for the Island of Kastellorizo I

## Proposed RES Power Generating Units

- (a) Wind turbines (WT): 750 kW (3x 250kW)
- (b) Photovoltaic Stations (PV): 2,300 kWp (monocrystalline PV )
- (c) Back up diesel generators 1,000 kW (2 X 500 kW/600KVA)
- (d) Li-ion Battery Energy Storage Systems 2 X 2.000 kWh/1.000 kW (C-rate 0.5)

## Annual Electricity Demand and Power Generation of the Proposed System



- Power demand: 4.722,3 MWh for 2025 (higher demand during the period June - October)
- Annual Windpower Generation: 4.165 MWh
- Annual Solar Power Generation: 3.882 MWh
- Energy from RES utilized to cover the demand : 3.974,95 MWh
- Electricity discharged from battery system : 433,49 MWh
- Energy Curtailment of the RES system: 3.638 MWh (including battery charge/discharge losses)
- Back-Up Diesel Generator: 312,9 MWh

## RES Penetration

- **93.37%** annually, with energy storage and DSM techniques for electricity demand for water desalination



# The New Energy System for the Island of Kastellorizo II



- Currently Installed MV Power distribution network
- MV distribution network extension
- Substations
- Electricity Storage System
- Automated Control Center
- Solar PV Station
- Wind Turbine
- Backup Diesel Generator Unit
- MV Submarine Cable





# Economic Evaluation for Proposed Energy System

For the Economic Evaluation of the New Power System we utilized:


## Levelized Cost of Electricity (LCOE)

$$LCOE = \frac{CAPEX + \sum_{n=1}^N \frac{OPEX}{(1+r)^n} - \frac{RV}{(1+r)^{N+1}}}{\sum_{n=1}^N \frac{Y_o - (1-D)^n}{(1+r)^n}}$$

Cost of Electricity:



\* average full cost of power generation for the current power station of Megisti (Kastellorizo)



## Conclusions – Key points of the study

---

- The problem of high electricity costs and high greenhouse gas emissions of electricity supply in Kastellorizo Island can be addressed.
- This solution is characterized by high CAPEX (5.5m) but also by **very low running costs, stable generation costs over a long period of time and higher security of energy supply.**
- High installed capacity of RES (3.05 MW) for the island's proposed system compared to the current diesel power plant (1.45 MW).
- Energy Storage **mainly exploits the excess solar power generation of the day during the night hours**, a phenomenon that is mainly enhanced in the summer months,
- Required adaptations of the **legal framework** for NII energy systems, these should include specific studies for each island separately, focusing on security of supply, oil dependence, high RES penetration (70% - 90%) and thereby drastically reducing greenhouse gas emissions.

# IENE Study: “Feasibility Study of Energy Storage Systems’ Integration in Crete” (M53) (Collaboration with IPTO).

---



# Scenarios

---

- Two reference years

2022 :

- Deployed Peloponnese – Crete AC interconnector
- Examination of two electricity demand profiles
- Assessment of BESS in an event of circuit disconnection at AC interconnector under a high electricity demand conditions

2030:

- Deployed DC interconnector Attica – Crete
- Examination of two electricity demand profiles
- Examination of two RES generation profiles
- Assessment of BESS with/without the deployment of Amari hybrid power station (pump storage unit)
- Assessment of BESS with/without the deployment of an efficient Gas-fired CCGT
- Assessment of BESS in an event of a DC pole disconnection at DC interconnector under various conditions

# Analysis Methodology

- Crete UCED+S model developed by IENE – Mixed-integer linear programming tool. – Cost optimization (minimization)
  - Deterministic model
  - Thermal cycle of available thermal units (ramp-up/down, min up/down time, technical minimum output etc.)
  - Grid constraints: spatial constraints, spinning reserves etc.
  - RES generation
  - Electricity Demand
  - Costs: generation costs (variable, start-up/down costs, RES curtailment costs, cost of imported electricity (deterministic), etc.)
  - Battery operation constraints (set points, maximum DoD, roundtrip efficiency etc.)
- Crete UCED+S model : tailor-made for the elaboration of the specific study.
- Scope of the analysis is:
  - The cost optimization and the reduction of oil use in Crete for 2022 with the integration of BESS
  - The reduction of the RES curtailment and cost reduction under various adequacy concerning circumstances for Crete in 2030 with the integration of BESS




Figure 2 Nodal depiction of CRETE-UC+S model's function for the 2030 scenarios (Note: the display of thermal power plants in the nodal diagram (in grey) is indicative)

# BESS integration in 2022 – Indicative results

## BAU22 Scenario: Reduction of oil use in Crete

- 100MW/400MWh : -5.6% power generation from oil units
- 100MW/400MWh: -73.2% of thermal units start ups




Figure 5 Power generation from conventional oil units in Crete for BAU22 scenario after the integration of various BESS.




Figure 4 Annual maximum hourly average load demand covered by conventional oil units in Crete for BAU22 scenario after the integration of various BESS.




Figure 2 Economic benefit for the integration of various BESS in the system of Crete under all examined scenarios





Figure 3 Economic benefit after depreciation for the integration of various BESS in the system of Crete under BAU22 scenario

# BESS integration in 2030 – Indicative results

- Central BESSs’ integration is economically infeasible due to very high investment capital costs.
- Economic feasibility occurs under circumstances of:
  - In an event of one pole disconnection at DC cable interconnector Attica-Crete (2 months) for BESS storage capacities ranging from 50MWh - 100MWh for BAU scenario and for any integrated BESS storage capacity under increased demand conditions
- RES Curtailment occurs only under a high RES integration scenario that includes aggregated RES capacity of 2,550 MW in Crete (RES curtailment of 9.17%, at 622 GWh/year). In this case there utility value of BESS but still BESS integration remains economically infeasible.







**INSTITUTE OF ENERGY**  
**FOR SOUTH-EAST EUROPE**

---

**Thank you very much for your attention!**

**[www.iene.gr](http://www.iene.gr)**

**[aperellis@iene.gr](mailto:aperellis@iene.gr)**

**[aperellis@gmail.com](mailto:aperellis@gmail.com)**